



中国节能产品认证证书

证书编号：CQC19701225439

申请人名称及地址：安徽皖南电机股份有限公司
安徽省宣城市泾县泾川镇南华路86号

品 牌：皖南电机

制造商名称及地址：安徽皖南电机股份有限公司
安徽省宣城市泾县泾川镇南华路86号

生产企业名称及地址：安徽皖南电机股份有限公司
安徽省宣城市泾县泾川镇南华路86号

产 品 名 称：超高效率三相异步电动机

系 列/规 格/型 号：见附件

认 证 模 式：产品型式试验+初次工厂检查+获证后监督

产品标准/技术要求：GB18613-2012

上述产品符合 CQC31-461121-2009 认证规则的要求，特此发证。

证 书 有 效 期：2019年08月14日至2022年08月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



主任：

陆梅



中国质量认证中心



CHINA CERTIFICATE FOR ENERGY CONSERVATION PRODUCT

CERTIFICATE NO.: CQC19701225439

NAME AND ADDRESS OF THE APPLICANT:	ANHUI WANNAN ELECTRIC MACHINE CO.,LTD. 86, Nanhua Road, Jingchuan Town, Jingxian County, Anhui Province
BRAND NAME:	皖南电机
NAME AND ADDRESS OF THE MANUFACTURER:	ANHUI WANNAN ELECTRIC MACHINE CO.,LTD. 86, Nanhua Road, Jingchuan Town, Jingxian County, Anhui Province
NAME AND ADDRESS OF THE FACTORY:	Anhui Wannan Electric Machine Co.,Ltd 86, Nanhua Road , Jingchuan Town, Jingxian County ,Anhui Province
PRODUCT NAME:	YE3 Series Super-High Efficiency Three Phase Induction motors
PRODUCT MODEL AND SPECIFICATION:	See Appendix
TYPE OF CERTIFICATION SCHEMES:	Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection
THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS:	GB18613-2012

This is to certify that the above mentioned product(s) complies with the requirements of CQC31-461121-2009 .

Valid from: Aug.14,2019

Valid until: Aug.14,2022

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC19701225439

第 1 页 共 10 页

Page 1 of 10

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
1.	YE3-80M1-2	380	50	0.75	2P	F	IP55	S1	2
2.	YE3-80M2-2	380	50	1.1	2P	F	IP55	S1	2
3.	YE3-80M2-4	380	50	0.75	4P	F	IP55	S1	2
4.	YE3-90S-2	380	50	1.5	2P	F	IP55	S1	2
5.	YE3-90L-2	380	50	2.2	2P	F	IP55	S1	2
6.	YE3-90S-4	380	50	1.1	4P	F	IP55	S1	2
7.	YE3-90L-4	380	50	1.5	4P	F	IP55	S1	2
8.	YE3-90S-6	380	50	0.75	6P	F	IP55	S1	2
9.	YE3-90L-6	380	50	1.1	6P	F	IP55	S1	2
10.	YE3-100L-2	380	50	3	2P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

第 2 页 共 10 页
Page 2 of 10

证书编号: CQC19701225439

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
11.	YE3-100L1-4	380	50	2.2	4P	F	IP55	S1	2
12.	YE3-100L2-4	380	50	3	4P	F	IP55	S1	2
13.	YE3-100L-6	380	50	1.5	6P	F	IP55	S1	2
14.	YE3-112M-2	380	50	4	2P	F	IP55	S1	2
15.	YE3-112M-4	380	50	4	4P	F	IP55	S1	2
16.	YE3-112M-6	380	50	2.2	6P	F	IP55	S1	2
17.	YE3-132S1-2	380	50	5.5	2P	F	IP55	S1	2
18.	YE3-132S2-2	380	50	7.5	2P	F	IP55	S1	2
19.	YE3-132S-4	380	50	5.5	4P	F	IP55	S1	2
20.	YE3-132M-4	380	50	7.5	4P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC19701225439

第 3 页 共 10 页
Page 3 of 10

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
21.	YE3-132S-6	380	50	3	6P	F	IP55	S1	2
22.	YE3-132M1-6	380	50	4	6P	F	IP55	S1	2
23.	YE3-132M2-6	380	50	5.5	6P	F	IP55	S1	2
24.	YE3-160M1-2	380	50	11	2P	F	IP55	S1	2
25.	YE3-160M2-2	380	50	15	2P	F	IP55	S1	2
26.	YE3-160L-2	380	50	18.5	2P	F	IP55	S1	2
27.	YE3-160M-4	380	50	11	4P	F	IP55	S1	2
28.	YE3-160L-4	380	50	15	4P	F	IP55	S1	2
29.	YE3-160M-6	380	50	7.5	6P	F	IP55	S1	2
30.	YE3-160L-6	380	50	11	6P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC19701225439

第 4 页 共 10 页
Page 4 of 10

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
31.	YE3-180M-2	380	50	22	2P	F	IP55	S1	2
32.	YE3-180M-4	380	50	18.5	4P	F	IP55	S1	2
33.	YE3-180L-4	380	50	22	4P	F	IP55	S1	2
34.	YE3-180L-6	380	50	15	6P	F	IP55	S1	2
35.	YE3-200L1-2	380	50	30	2P	F	IP55	S1	2
36.	YE3-200L2-2	380	50	37	2P	F	IP55	S1	2
37.	YE3-200L-4	380	50	30	4P	F	IP55	S1	2
38.	YE3-200L1-6	380	50	18.5	6P	F	IP55	S1	2
39.	YE3-200L2-6	380	50	22	6P	F	IP55	S1	2
40.	YE3-225M-2	380	50	45	2P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC19701225439

第 5 页 共 10 页
Page 5 of 10

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
41.	YB3-225S-4	380	50	37	4P	F	IP55	S1	2
42.	YB3-225M-4	380	50	45	4P	F	IP55	S1	2
43.	YB3-225M-6	380	50	30	6P	F	IP55	S1	2
44.	YB3-250M-2	380	50	55	2P	F	IP55	S1	2
45.	YB3-250M-4	380	50	55	4P	F	IP55	S1	2
46.	YB3-250M-6	380	50	37	6P	F	IP55	S1	2
47.	YE3-280S-2	380	50	75	2P	F	IP55	S1	2
48.	YE3-280M-2	380	50	90	2P	F	IP55	S1	2
49.	YE3-280M1-2	380	50	110	2P	F	IP55	S1	2
50.	YE3-280S-4	380	50	75	4P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

第 6 页 共 10 页
Page 6 of 10

证书编号: CQC19701225439

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
51.	YE3-280M-4	380	50	90	4P	F	IP55	S1	2
52.	YE3-280M1-4	380	50	110	4P	F	IP55	S1	2
53.	YE3-280S-6	380	50	45	6P	F	IP55	S1	2
54.	YE3-280M-6	380	50	55	6P	F	IP55	S1	2
55.	YE3-280M1-6	380	50	75	6P	F	IP55	S1	2
56.	YE3-315S-2	380	50	110	2P	F	IP55	S1	2
57.	YE3-315M-2	380	50	132	2P	F	IP55	S1	2
58.	YE3-315L1-2	380	50	160	2P	F	IP55	S1	2
59.	YE3-315L-2	380	50	185	2P	F	IP55	S1	2
60.	YE3-315L2-2	380	50	200	2P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

第 7 页 共 10 页
Page 7 of 10

证书编号: CQC19701225439

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
61.	YE3-315L3-2	380	50	220	2P	F	IP55	S1	2
62.	YE3-315L4-2	380	50	250	2P	F	IP55	S1	2
63.	YE3-315S-4	380	50	110	4P	F	IP55	S1	2
64.	YE3-315M-4	380	50	132	4P	F	IP55	S1	2
65.	YE3-315L1-4	380	50	160	4P	F	IP55	S1	2
66.	YE3-315L-4	380	50	185	4P	F	IP55	S1	2
67.	YE3-315L2-4	380	50	200	4P	F	IP55	S1	2
68.	YE3-315L3-4	380	50	220	4P	F	IP55	S1	2
69.	YE3-315L4-4	380	50	250	4P	F	IP55	S1	2
70.	YE3-315S-6	380	50	75	6P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

第 8 页 共 10 页
Page 8 of 10

证书编号: CQC19701225439

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
71.	YE3-315M-6	380	50	90	6P	F	IP55	S1	2
72.	YE3-315L1-6	380	50	110	6P	F	IP55	S1	2
73.	YE3-315L2-6	380	50	132	6P	F	IP55	S1	2
74.	YE3-315L3-6	380	50	160	6P	F	IP55	S1	2
75.	YE3-315L4-6	380	50	185	6P	F	IP55	S1	2
76.	YE3-355M1-2	380	50	220	2P	F	IP55	S1	2
77.	YE3-355M-2	380	50	250	2P	F	IP55	S1	2
78.	YE3-355L1-2	380	50	280	2P	F	IP55	S1	2
79.	YE3-355L-2	380	50	315	2P	F	IP55	S1	2
80.	YE3-3551-2	380	50	355	2P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

第 9 页 共 10 页
Page 9 of 10

证书编号: CQC19701225439

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
81.	YE3-3552-2	380	50	375	2P	F	IP55	S1	2
82.	YE3-355M1-4	380	50	220	4P	F	IP55	S1	2
83.	YE3-355M-4	380	50	250	4P	F	IP55	S1	2
84.	YE3-355L1-4	380	50	280	4P	F	IP55	S1	2
85.	YE3-355L-4	380	50	315	4P	F	IP55	S1	2
86.	YE3-3551-4	380	50	355	4P	F	IP55	S1	2
87.	YE3-3552-4	380	50	375	4P	F	IP55	S1	2
88.	YE3-355M1-6	380	50	160	6P	F	IP55	S1	2
89.	YE3-355M-6	380	50	185	6P	F	IP55	S1	2
90.	YE3-355M2-6	380	50	200	6P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心



中国节能产品认证证书

附录
APPENDIX

证书编号: CQC19701225439

第 10 页 共 10 页
Page 10 of 10

纸号: 155211

序号	型号	电压 (V)	频率 (Hz)	额定功率 (kW)	极数	绝缘等级	防护等级	工作制	能效等级
91.	YE3-355L1-6	380	50	220	6P	F	IP55	S1	2
92.	YE3-355L-6	380	50	250	6P	F	IP55	S1	2
93.	YE3-3551-6	380	50	280	6P	F	IP55	S1	2
94.	YE3-3552-6	380	50	315	6P	F	IP55	S1	2
95.	YE3-355L4-6	380	50	355	6P	F	IP55	S1	2

注: 此附录与证书同时使用时有效。

NOTE: This appendix is valid when used with the certificate.



主任:

陆梅



中国质量认证中心